

GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From :

The Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

To :

The Management,
M/s Bharatheeya Vidyabavan,
Vidyashramam, R.S.No.419,
429, Bhimavaram,
West Godavari District.

.....
Rc.No.11519/WG/DFO/2020, (MSB-ER), Dated: 08-07-2022.

Sir,

Sub: A.P. State Disaster Response and Fire Services Department-MSB Section-Issuance of Renewal of No Objection Certificate to the Existing Building of M/s Bharatheeya Vidyabavan, represented by U.R.K.Raju, Vidyashramam, R.S.No.419, 429, Bhimavaram, West Godavari District -Regarding.

- Ref: 1. Occupancy NOC Rc.No.11519/WG/DFO/2020, Dt:06.02.2020 of District Fire Officer, West Godavari District.
2. Application of M/s Bharatheeya Vidyabavan, represented by U.R.K.Raju, Vidyashramam, R.S.No.419, 429, Bhimavaram, West Godavari District.

The Management of M/s Bharatheeya Vidyabavan, represented by U.R.K.Raju, Vidyashramam, R.S.No.419, 429, Bhimavaram, West Godavari District has requested to issue Renewal of No Objection Certificate by duly remitting the Renewal Fee towards Fire Precautionary Fee vide reference 2nd cited.

2) The No Objection Certificate for Occupancy was issued vide reference 1st cited to the Existing Building of M/s Bharatheeya Vidyabavan, represented by U.R.K.Raju, Vidyashramam, R.S.No.419, 429, Bhimavaram, West Godavari District with Ground + 02 Upper Floors with Built-up area of 5844.90 Sq.Mtrs., with a Height of 09.90 Mtrs., for Educational Occupancy.

3) The Management has submitted the Self-Certification report and stated that the furnished information is correct and it is noticed at any time that the information provided is false, they understand that Renewal NOC deemed may be cancelled by the concerned authority.

4) In view of the above and taking into consideration of the larger public interest and in the context of the COVID-19 pandemic across the country and also based on the Self-Certification submitted by the Management, the Renewal of No Objection Certificate is issued to the Existing Building of M/s Bharatheeya Vidyabavan, represented by U.R.K.Raju, Vidyashramam, R.S.No.419, 429, Bhimavaram, West Godavari District with Ground + 02 Upper Floors with Built-up area of 5844.90 Sq.Mtrs., with a Height of 09.90 Mtrs., for Educational Occupancy.

(contd....2p)

5) It is suggested to the Management for providing the following Fire Safety Measures keeping in view of Practicality, Maintenance and Resilience.

| Sl. No. | Fire Fighting Equipment | Prescribed | Available with Nos. | Deficit |
|---------|--|--|---------------------|---------|
| 1 | Staircases | Minimum (02) shall be Provided. If the Second Staircase is not possible, provide Slider or Tube Lift with Exhaust Fan (connected outside to Building) or German Chute or Horizontal connection between the neighborhood Buildings. | 02 No's. | Nil |
| 2 | Fire Extinguishers | ABC/CO2 type | 60 No's. | Nil |
| 3 | Underground parking/ Cellar / Basement | Temperature Sensors connected to "Hooter" and that can be give alerts through Cell phone instead of Sprinklers. | NA | Nil |
| 4 | Manual Call Point System | One Number per Floor | 03 No's. | Nil |
| 5 | Under Ground Static Water Tank (or) Terrace Water Tank. | 10,000 Ltrs. (Minimum) | 10,000 Ltrs. | Nil |
| 6 | 2 HP (Pump + Electrical Motors connected) @ one per Floor connected to Normal Plumbing System instead of Down Comer/Special Pipes. | One per each Floor (Total 03 Floors) | 03 No's. | Nil |
| 7 | 5 HP (Mobile Pump + Petrol Engine on wheels connected to Ground Floor Sump). | One per each Floor | 02 No's. | Nil |
| 8 | Display the mentioned Phone Nos. at important areas. | (i) Fire Department Number (ii) Ambulance (iii)Police | Displayed | Nil |

6) The Management has provided the following Electrical Safety system.


| | | | |
|--------|--|---|----------|
| (i) | All Electrical wirings in the Building shall confirm the code of practise for Electrical wiring IS:732:1989 and also shall confirm for Fire Safety Wiring of the Building Electrical Installations as per IS:1646:2015. Most common mistake is that the neutral wires to the Three Pin plugs are not of sufficient thickness to carry the current in case of any Short Circuits. | : | Provided |
| (ii) | Installation of Miniature Circuit Breakers (MCB's) and to protect high power intensive equipment such as Cath Labs etc., | : | Provided |
| (iii) | No Overloading of Power Sockets. | : | Provided |
| (iv) | Electrical wiring to be changed for every ten years, wherever high power consuming appliances such as Air Conditioners etc., | : | Provided |
| (v) | LED lights in Closed Rooms, Corridors, Staircases connected to Inverter (Battery) to ensure well light pathways for Exit or Evacuation inspite of regular power failure in any Emergency. | : | Provided |
| (vi) | Grounding/Earthing Shall be done. For details refer IS 3043:1987. | : | Provided |
| (vii) | To install non pressurized Aerosol suppression system (or) CO2 Flooding system in Electrical Panel Rooms. | : | Provided |
| (viii) | Lightening Conductors shall be provided for more than 05 Floors Building. | : | NA |
| (ix) | All the above Safety Measures shall be Certified by the authorized Electrical Engineer. | : | Yes |

7) Fire Safety Suggestions:

| Sl. No. | As Builder | As Occupant | As Security personnel |
|---------|--|--|---|
| 1. | All the Fire protection arrangements shall be maintained in good working condition at all time. | The Escape/Exit roots shall not be kept Locked/Blocked or Encroached. | All the Occupants must be trained the correct method of operation of the Fire Fighting system installed. |
| 2. | Any loss of life or property due to non-functioning of Fire Safety Measures and other Installations shall be the responsibility of the Management. | All Occupants shall be trained to operate the Fire Safety Equipment during Emergency. | Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months. |
| 3. | Addition/Alteration, if any in the Building may be verified by Building Authority. | Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months. | All Security Personnel shall be trained to operate the Fire Safety Equipment during Emergency. |
| 4. | This Renewal of No Objection Certificate is only from Fire Safety Point of View. | Raise the alarm If the Fire cannot be controlled, Evacuate the area completely at once with nearest Safe Exit. | Attack the Fire using available Fire Equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing Doors and Windows. |

8) This Renewal of No Objection Certificate is valid for a period of Five (05) years from the date of issue of this letter to the Management of M/s Bharatheeya Vidyabavan, represented by U.R.K.Raju, Vidyashramam, R.S.No.419, 429, Bhimavaram, West Godavari District subject to the compliance of above Fire and Electrical Safety Measures. The Owner/Occupier/Builder/Management concerned of the Building shall submit Affidavit/Self Declaration/Certification with regard to working condition of above Fire Safety System every year in the prescribed format and submit/upload the photographs of the Mock Drills conducted in the premises. It is the responsibility of the Builder to maintain the Fire Safety Equipment in good working condition at all times and apply for next Periodical Renewal of No Objection Certificate, duly remitting the User Charges vide G.O.Ms.No.90, Home (Prisons & Fire Services) Department, Dated:13.08.2021 & G.O.Ms.No.120, Home (Prisons & Fire Services) Department, Dated:25.10.2021, two (02) months before expiry of this Renewal of No Objection Certificate.

Yours Sincerely,



Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

Copy to the District Educational Officer, West Godavari District.

Note: In case of any emergency call to 101 or State Fire Control Room-9100108101.